

Test Verification of Conformity

Verification Number: 161118015GZU-002 amendment 2

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>. This verification replaces previous verification 161118015GZU-002 amendment 1 dated 08 November 2017

relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & SHENZHEN GROWATT NEW ENERGY TECHNOLOGY CO., LTD

Address: 1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28,

GuangHui Road, LongTeng Community, Shiyan Street, Baoan District,

Shenzhen, P.R.China

Product Description: PV Grid inverter

Models/Type References: Growatt 3000 TL3-S, Growatt 4000 TL3-S, Growatt 5000 TL3-S,

Growatt 6000 TL3-S, Growatt 7000 TL3-S, Growatt 8000 TL3-S Growatt 9000 TL3-S, Growatt 10000 TL3-S, Growatt 11000 TL3-S

Ratings & Principle See Appendix

Characteristics:

Brand Name(s): GROWATT

Standard(s)/Directive(s): EN 61000-6-1:2007

EN 61000-6-3:2007+A1: 2011

EN 61000-6-2:2005

EN 61000-6-4:2007+A1:2011 EMC Directive 2014/30/EU

Verification Issuing Office

Name & Address:

Intertek Testing Services Shenzhen Ltd. Guangzhou Branch

Block E, No.7-2 Guang Dong Software Science Park, Caipin Road,

Guangzhou Science City, GETDD Guangzhou, China

Test Report Number(s): 161118015GZU-002 amendment 2

Additional information in Appendix.

Signature

Name: Helen Ma

Position: Team Leader Date: 28 June 2018

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 161118015GZU-002 amendment 2

Ratings & Principle Characteristics:

For model: Growatt 3000 TL3-S

DC input:

Max. PV Voltage: 1000Vdc; DC Voltage Range: 140-1000Vdc;

MPPT Voltage Range: 160-800Vdc; PV lsc: 16A/16A

AC output:

Max. Apparent Power: 3.0kVA; Max Output Current: 3*4.5A; Nominal Output Voltage: 3W/N/PE 230Vac/400Vac; Nominal Fre-

quency: 50Hz; Power Factor: 0.8 Leading - 0.8 Lagging

Ambient Temperature: -25 °C - +60 °C

IP65, Class I

For model: Growatt 4000 TL3-S

DC input:

Max. PV Voltage: 1000Vdc; DC Voltage Range: 140-1000Vdc;

MPPT Voltage Range: 200-800Vdc; PV Isc: 16A/16A

AC output:

Max. Apparent Power: 4.0kVA; Max Output Current: 3*6.1A; Nominal Output Voltage: 3W/N/PE 230Vac/400Vac; Nominal Fre-

quency: 50Hz; Power Factor: 0.8 Leading - 0.8 Lagging

Ambient Temperature: -25 °C - +60 °C

IP65, Class I

For model: Growatt 50000 TL3-S

DC input:

Max. PV Voltage: 1000Vdc; DC Voltage Range: 140-1000Vdc;

MPPT Voltage Range: 250-800Vdc; PV lsc: 16A/16A

AC output:

Max. Apparent Power: 5.0kVA; Max Output Current: 3*7.6A; Nominal Output Voltage: 3W/N/PE 230Vac/400Vac; Nominal Fre-

quency: 50Hz; Power Factor: 0.8 Leading - 0.8 Lagging

Ambient Temperature: -25℃ - +60℃

IP65, Class I

For model: Growatt 6000 TL3-S

DC input:

Max. PV Voltage: 1000Vdc; DC Voltage Range: 140-1000Vdc;

MPPT Voltage Range: 290-800Vdc; PV Isc: 16A/16A

AC output:

Max. Apparent Power: 6.0kVA; Max Output Current: 3*9.1A; Nominal Output Voltage: 3W/N/PE 230Vac/400Vac; Nominal Frequen-

cy: 50Hz; Power Factor: 0.8 Leading - 0.8 Lagging

Ambient Temperature: -25℃ - +60℃

IP65, Class I

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



For model: Growatt 7000 TL3-S

DC input: Max. PV Voltage: 1000Vdc; DC Voltage Range: 160-1000Vdc; MPPT Voltage Range: 320-850Vdc; PV Isc: 16A/16A

Max. Apparent Power: 7.7kVA; Max Output Current: 3*11.7A; Nominal Output Voltage: 3W/N/PE 230Vac/400Vac; Nominal Fre-

quency:

50Hz; Power Factor: 0.8 Leading - 0.8 Lagging

Ambient Temperature: -25 °C - +60 °C

IP65, Class I

For model: Growatt 8000 TL3-S

DC input:

Max. PV Voltage: 1000Vdc; DC Voltage Range: 160-1000Vdc;

MPPT Voltage Range: 360-850Vdc; PV Isc: 16A/16A

Max. Apparent Power: 8.8kVA; Max Output Current: 3*13.3A;

Nominal Output Voltage: 3W/N/PE 230Vac/400Vac; Nominal Frequency: 50Hz; Power Factor:0.8 Leading – 0.8 Lagging

Ambient Temperature: -25℃ - +60℃

IP65, Class I

For model: Growatt 9000 TL3-S

DC input:

Max. PV Voltage: 1000Vdc; DC Voltage Range: 160-1000Vdc; MPPT Voltage Range: 400-850Vdc; PV Isc: 16A/16A

AC output:

Max. Apparent Power: 9.9kVA; Max Output Current: 3*15A; Nominal Output Voltage: 3W/N/PE 230Vac/400Vac; Nominal Frequen-

cy: 50Hz; Power Factor: 0.8 Leading - 0.8 Lagging

Ambient Temperature: -25℃ - +60℃

IP65, Class I

For model: Growatt 10000 TL3-S

DC input:

Max. PV Voltage: 1000Vdc; DC Voltage Range: 160-1000Vdc;

MPPT Voltage Range: 450-850Vdc; PV Isc: 16A/16A

AC output:

Max. Apparent Power: 11kVA; Max Output Current: 3*16.7A; Nominal Output Voltage: 3W/N/PE 230Vac/400Vac; Nominal Frequen-

cy: 50Hz; Power Factor: 0.8 Leading - 0.8 Lagging

Ambient Temperature: -25℃ - +60℃

IP65, Class I

For model: Growatt 11000 TL3-S

DC input:

Max. PV Voltage: 1000Vdc; DC Voltage Range: 160-1000Vdc; MPPT Voltage Range: 450-850Vdc; PV lsc: 16A/16A

Max. Apparent Power: 12.1kVA; Max Output Current: 3*18.3A; Nominal Output Voltage: 3W/N/PE 230Vac/400Vac; Nominal Fre-

quency: 50Hz; Power Factor:0.8 Leading - 0.8 Lagging

Ambient Temperature: -25 °C - +60 °C

IP65, Class I

Signature

Name: Helen Ma

Helen

Position: Team Leader Date: 28 June 2018

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.