


Certificate of Conformity

Certificate Number: CN-PV-200092

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specifications /standards at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Shenzhen Growatt New Energy Technology CO., Ltd 1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng Community, Shiyan Street, Baoan District, Shenzhen, P.R.China
Product:	PV Grid inverter
Ratings & Principle Characteristics:	See Appendix to Certificate of Conformity
Models:	MOD 3000TL3-X, MOD 4000TL3-X, MOD 5000TL3-X, MOD 6000TL3-X, MOD 7000TL3-X, MOD 8000TL3-X, MOD 9000TL3-X, MOD 10KTL3-X, MOD 11KTL3-X, MOD 12KTL3-X, MOD 13KTL3-X, MOD 15KTL3-X
Brand Name:	Growatt
Tested according to:	IEC 61727:2004 Photovoltaic (PV) systems – Characteristics of the utility interface IEC 62116:2014 Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai 2/F (West Side), No. 707, Zhangyang Road, Free Trade Experimental Area, Shanghai, P. R. China
Test Reports No:	200427174GZU-001, 200427174GZU-002

Additional information in Appendix.



Signature

Certification Manager: Grady Ye

Date: 22 Jul 2020

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-200092

Ratings & Principle Characteristics:

Model	MOD 3000TL3-X	MOD 4000TL3-X	MOD 5000TL3-X	MOD 6000TL3-X
Max. PV voltage	1100Vdc			
PV voltage range	140 – 1000Vdc			
PV Isc	2*16A			
Max. input current	2*13A			
Max. output power	3000W	4000W	5000W	6000W
Max. apparent power	3300VA	4400VA	5500VA	6600VA
Nominal output voltage	3W/N/PE 230/400Vac			
Max. output current	5.0A	6.7A	8.3A	10.0A
Nominal output frequency	50/60Hz			
Power factor range	0.8Leading ~ 0.8Lagging			
Safety level	Class I			
Ingress protection	IP66			
Operation ambient temperature	-25°C - +60°C			
Software version	DL 1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-200092

Ratings & Principle Characteristics:

Model	MOD 7000TL3-X	MOD 8000TL3-X	MOD 9000TL3-X	MOD 10KTL3-X
Max. PV voltage	1100Vdc			
PV voltage range	140 – 1000Vdc			
PV Isc	2*16A			
Max. input current	2*13A			
Max. output power	7000W	8000W	9000W	10000W
Max. apparent power	7700VA	8800VA	9900VA	11000VA
Nominal output voltage	3W/N/PE 230/400Vac			
Max. output current	11.7A	13.3A	15.0A	16.7A
Nominal output frequency	50/60Hz			
Power factor range	0.8Leading ~ 0.8Lagging			
Safety level	Class I			
Ingress protection	IP66			
Operation ambient temperature	-25°C - +60°C			
Software version	DL 1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-200092

Ratings & Principle Characteristics:

Model	MOD 11KTL3-X	MOD 12KTL3-X	MOD 13KTL3-X	MOD 15KTL3-X
Max. PV voltage	1100Vdc			
PV voltage range	140 – 1000Vdc			
PV Isc	2*16A	16/32A		
Max. input current	2*13A	13/26A		
Max. output power	11000W	12000W	13000W	15000W
Max. apparent power	12100VA	13200VA	14300VA	16500VA
Nominal output voltage	3W/N/PE 230/400Vac			
Max. output current	18.3A	20.0A	21.7A	25.0A
Nominal output frequency	50/60Hz			
Power factor range	0.8Leading ~ 0.8Lagging			
Safety level	Class I			
Ingress protection	IP66			
Operation ambient temperature	-25°C - +60°C			
Software version	DL 1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.