



# Certificate of Conformity

**Certificate No.:** 1988AP1219N027001  
**Equipment:** SOLAR INVERTER  
**Brand Name:**  HUAWEI  
**Test Model No.:** SUN2000-3KTL-M0, SUN2000-4KTL-M0, SUN2000-5KTL-M0, SUN2000-6KTL-M0, SUN2000-8KTL-M0, SUN2000-10KTL-M0, SUN2000-3KTL-M1, SUN2000-4KTL-M1, SUN2000-5KTL-M1, SUN2000-6KTL-M1, SUN2000-8KTL-M1, SUN2000-10KTL-M1  
**Applicant:** Huawei Technologies Co., Ltd.  
Administration Building, Headquarters of Huawei Technologies Co., Ltd.,  
Bantian, Longgang District, Shenzhen, 518129, P.R.C  
**Report No.:** PVNL191219N027

## Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with EN 50549-1:2019 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

## Applied rules and standards

### EN 50549-1:2019

Requirements for generating plants to be connected in parallel with distribution networks - Part 1-1: Connection to a LV distribution network - Generating plants up to and including Type B

### DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid  
At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.



**Name: James Huang**  
**Technical Manager/ New Energy Team**  
**Date: 2020-04-24**

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.  
Information given in this document is related to the tested specimen of the described electrical sample.