



Compliance Verification Report with the G98 Issue 1 Amendment 3 2018

Test record for Type A Inverter Connected Power Generating Modules

| | |
|--------------|--|
| Manufacturer | SMA Solar Technology AG |
| Address | Sonnenallee 1, 34266 Niestetal (Germany) |

| | |
|------------------------------|----------------------------------|
| Type Tested reference number | ZE_G98-1_SBx.x-1AV-41_en_10 |
| Generating Unit technology | Single phase inverter |
| Test house details | SMA Solar Technology AG |
| Test period | From 2019-03-18 until 2019-04-29 |

| Type reference | Max. apparent AC power (VA) | Rated AC power (W) | From FW Pack |
|----------------|-----------------------------|--------------------|--------------|
| SB6.0-1AV-41 | 6000 | 6000 | 1.01.32.R* |
| SB5.0-1AV-41 | 5000 | 5000 | 1.01.32.R* |
| SB4.0-1AV-41 | 4000 | 4000 | 1.01.32.R* |
| SB3.6-1AV-41 | 3680 | 3680 | 1.01.32.R* |
| SB3.0-1AV-41 | 3000 | 3000 | 1.01.32.R* |

The results of the G98/1 are summarized in this certificate. SMA declares that all units shipped to the UK, with at least the aforementioned FW version, are within the specifications and parameters set by the G98/1 Engineering Recommendation, Amendment 3 2018.

* only in combination with the configuration file (*.bck)

These settings cannot be changed by an installer, user or by any person without authorization from SMA.

Note that all tests were carried out with the biggest inverter of the family under test. The results for the other inverters of the family are equivalent.



Test Results

Power quality

| Harmonics as per BS EN 61000-3-2 | | | | | | | | |
|----------------------------------|----------------|----------------|----------|--------|--------|--------|---------------------|---|
| Order | Frequency [Hz] | Thresholds [A] | P/Pn [%] | | | | Max. NV / Limit [%] | |
| | | | 50 | | 100 | | | |
| | | | MV [A] | NV [A] | MV [A] | NV [A] | | |
| 2 | 100 | 1,08 | 0,014 | 0,026 | 0,020 | 0,037 | 3,41% | ✓ |
| 3 | 150 | 2,3 | 0,167 | 0,307 | 0,522 | 0,960 | 41,76% | ✓ |
| 4 | 200 | 0,43 | 0,006 | 0,011 | 0,006 | 0,011 | 2,57% | ✓ |
| 5 | 250 | 1,14 | 0,118 | 0,217 | 0,239 | 0,440 | 38,58% | ✓ |
| 6 | 300 | 0,3 | 0,006 | 0,011 | 0,006 | 0,011 | 3,68% | ✓ |
| 7 | 350 | 0,77 | 0,042 | 0,077 | 0,077 | 0,142 | 18,40% | ✓ |
| 8 | 400 | 0,23 | 0,004 | 0,007 | 0,005 | 0,009 | 4,00% | ✓ |
| 9 | 450 | 0,4 | 0,028 | 0,052 | 0,035 | 0,064 | 16,10% | ✓ |
| 10 | 500 | 0,184 | 0,004 | 0,007 | 0,005 | 0,009 | 5,00% | ✓ |
| 11 | 550 | 0,33 | 0,019 | 0,035 | 0,023 | 0,042 | 12,82% | ✓ |
| 12 | 600 | 0,153 | 0,003 | 0,006 | 0,004 | 0,007 | 4,80% | ✓ |
| 13 | 650 | 0,21 | 0,020 | 0,037 | 0,020 | 0,037 | 17,52% | ✓ |
| 14 | 700 | 0,131 | 0,003 | 0,006 | 0,004 | 0,007 | 5,60% | ✓ |
| 15 | 750 | 0,15 | 0,015 | 0,028 | 0,017 | 0,031 | 20,85% | ✓ |
| 16 | 800 | 0,115 | 0,003 | 0,006 | 0,003 | 0,006 | 4,80% | ✓ |
| 17 | 850 | 0,132 | 0,015 | 0,028 | 0,015 | 0,028 | 20,85% | ✓ |
| 18 | 900 | 0,102 | 0,002 | 0,004 | 0,003 | 0,006 | 5,40% | ✓ |
| 19 | 950 | 0,118 | 0,012 | 0,022 | 0,010 | 0,018 | 18,65% | ✓ |
| 20 | 1000 | 0,092 | 0,002 | 0,004 | 0,003 | 0,006 | 6,00% | ✓ |
| 21 | 1050 | 0,107 | 0,013 | 0,024 | 0,010 | 0,018 | 22,33% | ✓ |
| 22 | 1100 | 0,084 | 0,002 | 0,004 | 0,002 | 0,004 | 4,40% | ✓ |
| 23 | 1150 | 0,098 | 0,010 | 0,018 | 0,008 | 0,015 | 18,81% | ✓ |
| 24 | 1200 | 0,077 | 0,002 | 0,004 | 0,002 | 0,004 | 4,80% | ✓ |
| 25 | 1250 | 0,09 | 0,009 | 0,017 | 0,008 | 0,015 | 18,40% | ✓ |
| 26 | 1300 | 0,071 | 0,002 | 0,004 | 0,002 | 0,004 | 5,20% | ✓ |
| 27 | 1350 | 0,083 | 0,007 | 0,013 | 0,007 | 0,013 | 15,46% | ✓ |
| 28 | 1400 | 0,066 | 0,002 | 0,004 | 0,002 | 0,004 | 5,60% | ✓ |
| 29 | 1450 | 0,078 | 0,008 | 0,015 | 0,007 | 0,013 | 18,97% | ✓ |
| 30 | 1500 | 0,061 | 0,002 | 0,004 | 0,002 | 0,004 | 6,00% | ✓ |
| 31 | 1550 | 0,073 | 0,008 | 0,015 | 0,006 | 0,011 | 20,28% | ✓ |
| 32 | 1600 | 0,058 | 0,002 | 0,004 | 0,002 | 0,004 | 6,40% | ✓ |
| 33 | 1650 | 0,068 | 0,009 | 0,017 | 0,007 | 0,013 | 24,29% | ✓ |
| 34 | 1700 | 0,054 | 0,002 | 0,004 | 0,002 | 0,004 | 6,80% | ✓ |
| 35 | 1750 | 0,064 | 0,008 | 0,015 | 0,006 | 0,011 | 22,90% | ✓ |
| 36 | 1800 | 0,051 | 0,002 | 0,004 | 0,002 | 0,004 | 7,20% | ✓ |
| 37 | 1850 | 0,061 | 0,007 | 0,013 | 0,006 | 0,011 | 21,18% | ✓ |
| 38 | 1900 | 0,048 | 0,002 | 0,004 | 0,002 | 0,004 | 7,60% | ✓ |
| 39 | 1950 | 0,058 | 0,006 | 0,011 | 0,006 | 0,011 | 19,14% | ✓ |
| 40 | 2000 | 0,046 | 0,002 | 0,004 | 0,003 | 0,006 | 12,00% | ✓ |

MV - Measured Value NV - Normalized Value $NV = MV * 3,68 / \text{power per phase}$

ZE_G98-1_SBx-x-1AV-41_en_10



| Active power operating range | | | | | |
|------------------------------|---------|-----------|--------|--------|--------------|
| Test | Voltage | Frequency | cosphi | Time | Verification |
| 1 | 195,5 V | 47,5 Hz | 1 | 90 min | ✓ |
| 2 | 253 V | 51,5 Hz | 1 | 90 min | ✓ |
| 3 | 253 V | 52 Hz | 1 | 15 min | ✓ |

Power quality

| Voltage fluctuations and flicker as per BS EN 61000-3-3 | | | | | | | | |
|---|----------|------|------------|----------|------|------------|---------|--------------|
| | Starting | | | Stopping | | | Running | |
| | dmax | dc | d(t) in ms | dmax | dc | d(t) in ms | Pst | Plt (2hours) |
| Limit | 4,0% | 3,3% | 500 | 4,0% | 3,3% | 500 | 1 | 0,65 |
| MV | 0,0% | 0,0% | 0 | 0,0% | 0,0% | 0 | 0,09 | 0,09 |
| Verification | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ |

| | DC injection | | | | P/Pn [%] | Power factor | | |
|--------------|--------------|-----------|----------|-----------|--------------|--------------|-------|-------|
| | P/Pn [%] | | | | | Voltage [V] | | |
| | 20 | 50 | 75 | 100 | | 216,2 | 230 | 253 |
| Limit | 0,25% In | 0,25% In | 0,25% In | 0,25% In | Limit | >0,95 | >0,95 | >0,95 |
| MV | 0,00396 A | 0,00792 A | 0,0106 A | 0,00646 A | 20 | 1,00 | 1,00 | 1,00 |
| %Inom | 0,02% | 0,03% | 0,04% | 0,02% | 50 | 1,00 | 1,00 | 1,00 |
| Verification | ✓ | ✓ | ✓ | ✓ | 75 | 1,00 | 1,00 | 1,00 |
| | | | | | 100 | 1,00 | 1,00 | 1,00 |
| | | | | | Verification | ✓ | ✓ | ✓ |

MV - Measured value

Protection - Grid monitoring and reconnection time

| Trip Tests | G98/1 | | Setting | | Measures Values | | Verification |
|------------------------|-----------|-------|-----------|-------|-----------------|---------|--------------|
| | Magnitude | Time | Magnitude | Time | Magnitude | Time | |
| Undervoltage | 184 V | 2,5 s | 184 V | 0,5 s | 183,246 V | 2,54 s | ✓ |
| Overtoltage stage 1 | 262,2 V | 1 s | 262,2 V | 1 s | 262,841 V | 1,04 s | ✓ |
| Overtoltage stage 2 | 273,7 V | 0,5 s | 273,7 V | 0,5 s | 274,355 V | 0,54 s | ✓ |
| Underfrequency stage 1 | 47,5 Hz | 20 s | 47,5 Hz | 20 s | 47,502 Hz | 20,12 s | ✓ |
| Underfrequency stage 2 | 47 Hz | 0,5 s | 47 Hz | 0,5 s | 47,004 Hz | 0,6 s | ✓ |
| Overfrequency | 52 Hz | 0,5 s | 52 Hz | 0,5 s | 52,054 Hz | 0,59 s | ✓ |

| No trip test | G98/1 | | Verification |
|--------------|-----------|--------|--------------|
| | Magnitude | Time | |
| U/V 1 | 188 V | 5,0 s | ✓ |
| U/V 2 | 180 V | 2,45 s | ✓ |
| O/V 1 | 258,2 V | 5,0 s | ✓ |
| O/V 2 | 269,7 V | 0,95 s | ✓ |
| O/V 3 | 277,7 V | 0,45 s | ✓ |

| No trip test | G98/1 | | Verification |
|--------------|-----------|--------|--------------|
| | Magnitude | Time | |
| U/F 1 | 47,7 Hz | 30 s | ✓ |
| U/F 2 | 47,2 Hz | 19,5 s | ✓ |
| U/F 3 | 46,8 Hz | 0,45 s | ✓ |
| O/F 1 | 51,8 Hz | 120 s | ✓ |
| O/F 2 | 52,2 Hz | 0,45 s | ✓ |

| Reconnection time | | | |
|-------------------|---------|---------|--------------|
| Limit | Setting | MV | Verification |
| 20 s | 20 s | 23,46 s | ✓ |

| No reconnection | | | |
|-----------------|----------|------------|------------|
| At 266,2 V | At 180 V | At 47,4 Hz | At 52,1 Hz |
| ✓ | ✓ | ✓ | ✓ |

ZE_G98-1_SBx-x-1AV-41_en_10



Protection - Loss of mains

| Loss of mains test according to the BS EN 62116 | | | | | | |
|---|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|----------------------------|
| Test power and imbalance | 28 % -5%Q (Test 22) | 58 % -5%Q (Test 12) | 100 % -5%P (Test 5) | 28 % +5%Q (Test 31) | 58 % +5%Q (Test 21) | 100 % +5%P (Test 10) |
| Trip time limit (s) | 0,5 | 0,5 | 0,5 | 0,5 | 0,5 | 0,5 |
| Measured Value L1 (s) | 0,3718 | 0,3666 | 0,4084 | 0,3824 | 0,3838 | 0,3968 |
| Measured Value L1L2L3 (s)* | 0 | 0 | 0 | 0 | 0 | 0 |
| Verification | ✓ | ✓ | ✓ | ✓ | ✓ | ✓ |

* Only applicable to three phase inverters

| Frequency change - Stability test | | | | |
|-----------------------------------|-----------------|-------------|---------------|--------------|
| | Start frequency | Change | End frequency | Verification |
| Positive vector shift | 49,0 Hz | +50 degrees | N/A | ✓ |
| Negative vector shift | 50,0 Hz | -50 degrees | N/A | ✓ |
| Positive frequency drift | 49 Hz | +0,95 Hz/s | 51 Hz | ✓ |
| Negative frequency drift | 51 Hz | -0,95 Hz/s | 49 Hz | ✓ |

Behavior in case of frequency changes

| Over-frequency test | | | | | | | | |
|---------------------|---------|---------|----------|--------------|-------------|----------|----------|--------------|
| Frequency | P > 80% | | | | P 40% - 60% | | | |
| | PDC | P (W) | Gradient | Verification | PDC | P (W) | Gradient | Verification |
| 50 Hz | 6217,62 | 5844 | N/A | ✓ | 3108,808 | 2930,659 | N/A | ✓ |
| 50,45 Hz | 6217,62 | 5779,46 | N/A | ✓ | 3108,808 | 2879,139 | N/A | ✓ |
| 50,70 Hz | 6217,62 | 5472,49 | -21,25% | ✓ | 3108,808 | 2728,839 | -20,88% | ✓ |
| 51,15 Hz | 6217,62 | 4955,23 | -19,89% | ✓ | 3108,808 | 2470,638 | -19,93% | ✓ |
| 50,70 Hz | 6217,62 | 5477,12 | 20,07% | ✓ | 3108,808 | 2733,697 | 20,30% | ✓ |
| 50,45 Hz | 6217,62 | 5783,24 | 21,19% | ✓ | 3108,808 | 2877,882 | 20,03% | ✓ |
| 50 Hz | 6217,62 | 5844,16 | N/A | ✓ | 3108,808 | 2918,953 | N/A | ✓ |

| Under-frequency test | | | | |
|----------------------|--------|-------|----------|--------------|
| Frequency | P = Pn | | | |
| | PDC | P (W) | Gradient | Verification |
| 50,00 Hz | 5790 | 5835 | N/A | ✓ |
| 49,55 Hz | 5790 | 5834 | N/A | ✓ |
| 47,55 Hz | 5790 | 5828 | 0,10% | ✓ |

Various requirements

| Fault level contribution | | |
|--------------------------|-------------|-------------|
| Time after fault | Voltage (V) | Current (A) |
| < 50 ms | 232,22 | 27,43 |
| 100 ms | 13,09 | 0,07 |
| 250 ms | 11,4 | 0,07 |
| 500 ms | 12,16 | 0,06 |
| Time to Trip | 0,53 | in seconds |

| Self monitoring - solid state switching |
|--|
| Not applicable as electro-mechanical relays are used |

| Active power curtailment |
|---|
| A Modbus signal can be used to cease Active Power output within 5 s |

ZE_G98-1_SBx-x-1AV-41_en_10